



HYDROGEOLOGIC DATABASE Chemical Analysis

[Click HERE to View Information for Well BX3](#)

Sample Results Color Code Legend

Sample Exceeds [None
Secondary
Primary] **MCL**



Owner Name: Northwest Colonial Homes

Well Key: BX3

Site Type: Well

TRS: 30N/02E-31Q

PWS Name: Goss Lake Road Water System

DOH PwsID: AA895

DOH Source #: 1

		Bicarbonate			Conductivity		Hardness			Turbidity						
Source	Date	Alk	As	Ca	Cl	Fe	K	Mg	Mn	Na	NO3	SO4	TDS			
DOH	10/28/2002		0.008		11	498	1.76	188			0.673	13	< 0.5	0.32	23	
DOH	7/26/2006										2.9					
DOH	12/30/2009										< 0.5					
DOH	12/27/2012										< 0.2					
DOH	12/29/2015										< 0.2					
DOH	12/19/2018										< 0.5					

Select Summary Statistics

Avg As:	0.008	Avg Cl:	11.0	Avg Hardness:	188	Avg NO3:	0.64
Median As:	0.008	Median Cl:	11.0	Median Hardness:	188	Median NO3:	0.25
Max As:	0.008	Max Cl:	11.0	Max Hardness:	188	Max NO3:	2.9

Bacteria Samples (distribution): [16 sample\(s\)](#)

Disclaimer: Data presented has been collected from a variety of sources. Island County makes no guarantee as to the validity or accuracy of this data.
Please report any errors to the Island County Hydrogeologist.

Generated by the Island County Hydrogeologic Database

6 records printed on 9/18/2019

Note: Items with [blue frames and blue text](#) are clickable hyperlinks to additional information / resources.

Parameter labels with a [red fill color](#) are exhibiting an increasing trend, and those with a [green fill color](#) are exhibiting a decreasing trend.